



# Compliance Statement

## ISO/IEC, EN & TIA/EIA Screened Class E<sub>A</sub> / Category 6A Four Connector Channel Reichle & De-Massari AG Binzstrasse 31 CHE-8622 Wetzikon, Switzerland

### Compliance Statement No. 109455

This type of Class E<sub>A</sub> / Category 6A screened four connector channel has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendment 1 to 2<sup>nd</sup> Edition ISO/IEC 11801, amendment 2 to 2<sup>nd</sup> Edition ISO/IEC 11801 (Draft 25N 1513), and amendment 1 to CENELEC EN 50173-1:2007 (Draft EN 50173-1 prAA June 2008), and Category 6A requirements of ANSI/TIA/EIA-568-B.2-10. The Compliance Statement is only valid for the actually tested channel samples in T568A designation and may be suspended or withdrawn if the channel fails to pass a Maintenance Testing performed at 12 month intervals. The channel consists of the following components with outlet and patch panels P/N R302387, P/N R305887, P/N R305120, and P/N R302362:

Cables from R&M:	Horizontal Cable, Flexible Cable, Qualification Status:	Real10 Cat. 7 P/N R35257 From Patch Cord, Real10 Cat. 6 P/N R302802 3P Verified Horizontal Cable and Manufacturer Verified Flexible Cable
Conn. Hardw. from R&M:	Connection Modules, Qualification Status:	P/N R302372 and P/N R304373 with De Luxe screen termination and having Preformed Inlay Conductors Manufacturer Verified
Patch cords from R&M:	2,0 metres and 5,0 metres Qualification Status:	Real10 Cat. 6 P/N R302334 and P/N R302336 Manufacturer Verified

Hoersholm, 6<sup>th</sup> August 2008

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 6<sup>th</sup> August 2008

*Paul Villien*

Poul Villien  
Coordinating Manager