



Compliance Statement

Screened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

YFC-BonEagle Identification P/N YLC-ESH04-LR-305XX

**Category 5e Overall Foil and Braid Screened
100 Ω , 4 Twisted Pairs, 24 AWG, Flame Retardant, LSFRHF, Copper Cable**

**YFC-BonEagle Electric Co., Ltd.
No. 12-9, Lane 130, Sec. 2, Chungshan E. Road
Hsinwu, Taoyuan, Taiwan, R.O.C.**

Compliance Statement No. 110535A

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2, 2nd edition IEC Cable Standard 61156-5 and the requirements of 2nd edition CENELEC Cable Standard EN 50288-2-1. Fire safety is verified according to IEC 60332-3-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 10th November 2011

Handwritten signature of Ole Lambertsen in blue ink.

Ole Lambertsen
Test Responsible

Hoersholm, 10th November 2011

Handwritten signature of Poul Villien in blue ink.

Poul Villien
Coordinating Manager