



Compliance Statement

Unscreened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

Premium-Line Identification P/N 2061421xy

Category 6, Unscreened

100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

Premium-Line Systems GmbH

Rosenheimer Strasse 89

D-83064 Raubling, Germany

Compliance Statement No. 110559B

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 6 requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and 2nd edition IEC Cable Standard 61156-5 and the requirements of CENELEC Cable Standard EN 50288-6-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 7. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 17th January 2012

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 17th January 2012

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien
Coordinating Manager