



# Compliance Statement

## ISO/IEC, EN & TIA/EIA Screened Class E<sub>A</sub> / Category 6A Three Connector Permanent Link

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CHE-8622 Wetzikon, Switzerland**

### *Compliance Statement No. 110560*

*This type of Class E<sub>A</sub> / Category 6A screened three connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendments 1 and 2 to 2<sup>nd</sup> Edition ISO/IEC 11801, amendment 1 to CENELEC EN 50173-1:2009, amendment 2 to CENELEC EN 50173-1 (Draft FprAB July 2010), and Category 6A requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the permanent link type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 12 month intervals. The permanent link consists of the following components, and when connected with RJ 45 plugs as from R&M cords, P/N R509863 and R511974:*

<i>Cables from R&amp;M:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>P/N R35257 P/N R318386 Manufacturer Verified</i>
<i>Conn. Hardw. from R&amp;M:</i>	<i>Connection Module,  Qualification Status:</i>	<i>P/N R50950x Module RJ45/s-C6A ISO-yy-zzz and P/N R510088 Module RJ45/s-C6A ISO-sp-100, having PCB Marking 16-0163 TL Manufacturer Verified</i>
<i>Cord from R&amp;M:</i>	<i>10,0 m Consolidation Cord Qualification Status:</i>	<i>P/N R509903 Manufacturer Verified</i>

Hoersholm, 15<sup>th</sup> September 2010

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 15<sup>th</sup> September 2010

*Paul Villien*

Poul Villien  
Coordinating Manager