



# Compliance Statement

## Screened Category 7<sub>A</sub> ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

### R&M Freenet, Type R319522

Category 7<sub>A</sub>, Individual Foil and Overall Braid Screened  
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSFRHF, Copper Cable

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CHE-8622 Wetzikon, Switzerland**

#### *Compliance Statement No. 110589B*

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7<sub>A</sub> performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 6<sub>A</sub> requirements of ANSI/TIA Generic Cabling Standard 568-C.2, 2<sup>nd</sup> edition IEC Cable Standard 61156-5, the requirements of 2<sup>nd</sup> edition CENELEC Cable Standard EN 50288-4-1 and Fpr EN 50288-9-1:2011. Fire Retardancy is verified according to IEC 60332-3-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment.1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 27<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 27<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager