



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class E_A / Category 6A Three Connector Channel

**YFC-BonEagle Electric Co., Ltd.
No. 12-9, Lane 130, Sec. 2, Chungshan E. Road
Hsinwu, Taoyuan, Taiwan, R.O.C.**

Attestation of Conformity No. 111729A

This type of Class E_A / Category 6A screened three connector channel has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of amendments 1 and 2 to 2nd Edition ISO/IEC 11801, amendment 1 to CENELEC EN 50173-1:2009, amendment 2 to CENELEC EN 50173-1 (Draft FprAB July 2010), and Category 6A requirements of ANSI/TIA-568-C.2. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following YFC-BonEagle Electric Co. components:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N YLC-APH04-xy-zzzcc (with PVC Sheath)</i>
	<i>Flexible Cable,</i>	<i>From Cords, P/N YLCP-APx-yyyMB-zz (in LSOH Version)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Keystone Jack,</i>	<i>P/N YKJ6-AFHL Die-Casting 180D Toolless Keystone Jack having PCB marking ABAFHDK0-0000001-IN</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Consolidation Cord:</i>	<i>10,0 m,</i>	<i>With Horizontal Cable, P/N YLC-APH04-xy-zzzcc (with PVC Sheath)</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Patch Cord:</i>	<i>5,0 m,</i>	<i>P/N YLCP-APx-yyyMB-zz (in LSOH Version)</i>

Hoersholm, 17th February 2011

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 17th February 2011

Paul Villien

Poul Villien
Coordinating Manager