



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class E<sub>A</sub> / Category 6A Two Connector Permanent Link

**Hsing Chau Industrial Co., Ltd.,  
9F, No. 39, Lane 513, Ruiguang Rd., Neihu District,  
Taipei City 114, Taiwan, R.O.C**

**Attestation of Conformity No. 111734**

*This type of Class E<sub>A</sub> / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendment 2 to 2<sup>nd</sup> Edition ISO/IEC 11801, amendment 2 to CENELEC EN 50173-1 (Draft FprAB July 2010), and Category 6A requirements of ANSI/TIA-568-C.2. The Attestation of Conformity is only valid for the actually tested permanent link samples in T568B configuration connected with RJ 45 plugs from Hsing Chau, P/N 0028SBR3A502, and consisting of the following components:*

<i>Cable:</i>	<i>Horizontal Cable from Draka Communications, P/N Silverline Gold 1000</i>
	<i>Qualification Status: Manufacturer verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jack from Hsing Chau, P/N 3013ALEFS6A</i>
	<i>Patch Panel from Hsing Chau: P/N BP242xM8S6A</i>
	<i>Qualification Status: having PCB Marking Cat.6 R001-87603 1F00</i>
	<i>having PCB Marking Cat.6A 001-0880 1F00</i>
	<i>Manufacturer Verified</i>

Hoersholm, 22<sup>nd</sup> December 2010

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 22<sup>nd</sup> December 2010

*Poul Villien*

Poul Villien  
Coordinating Manager