



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

### Brand-Rex Identification C6F/FTP-HF1

Category 6, Individual Foil and Overall Foil Screened  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

**Brand-Rex Limited**  
**Viewfield Industrial Estate, Glenrothes**  
**Fife KY6 2RS, Scotland**

*Compliance Statement No. 104311G*

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 6 requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and 2<sup>nd</sup> edition IEC Cable Standard 61156-5, and the requirements of 2<sup>nd</sup> edition CENELEC Cable Standard EN 50288-5-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 19<sup>th</sup> April 2012

Handwritten signature of Ole Lambertsen in blue ink.

Ole Lambertsen  
Test Responsible

Hoersholm, 19<sup>th</sup> April 2012

Handwritten signature of Poul Villien in blue ink.

Poul Villien  
Coordinating Manager