



# Compliance Statement

## Unscreened Category 6 ISO/IEC, EN & ANSI/TIA Communication Patch Cable

**TTL Network Identification 1720**  
Category 6, Patch, Unscreened  
100  $\Omega$ , 4 Twisted Pairs, 24 AWG, Flame Retardant, Copper Cable

**TTL Network GmbH**  
Weststrasse 87  
D-33790 Halle / Westfalen, Germany

*Compliance Statement No. 101157K*

*This Unscreened ISO/IEC, EN & ANSI/TIA Communication Patch Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 6 requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and 3<sup>rd</sup> edition IEC Cable Standard 61156-6 and the requirements of CENELEC Cable Standard EN 50288-6-2. Flame retardancy is verified according to IEC 60332-1-2. The cable has EMC Performance Rating 6. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 18<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 18<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager