



Compliance Statement

Screened Category 6_A ISO/IEC, EN & TIA Connecting Hardware

Telebox Identification P/N TB97A2Sx


Category 6_A, Screened Keystone Jack
Electrical Transmission Performance

Telebox Industries Corp.
4F, No. 306, Tatung Road, Sec. 1
Hsichih-Taipei 221, Taiwan, R.O.C.

Compliance Statement No. 115926C

This Screened ISO/IEC, EN & TIA Connecting Hardware having board identification "001-9769" has been tested by 3P Third Party Testing and complies with the Category 6_A transmission requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018 and IEC Connecting Hardware Standard 60603-7-51, and Category 6A transmission requirements of ANSI/TIA 568.2-D:2018. Testing is conducted as specified in IEC Test Standard 60512-27-100 and ANSI/TIA 568.2-D:2018. Requirements are passed using the complete specified re-embedded range of RJ 45 plug vectors. The qualification activity includes factory and assembly line inspection. The Compliance Statement will be suspended or withdrawn if the keystone jack fails to pass a Maintenance of Qualification Testing that is concluded not later than 31st December 2019.

Hoersholm, 21st December 2018



Ole Lambertsen
Test Responsible

Hoersholm, 21st December 2018



Jens Rytter Petersen
General Manager