



Attestation of Conformity

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Two Connector Channel


TELTRONIX LLP
Unit 1056 Moulton Park, Deer Park Road,
Northampton, NN3 6RX, U.K.

Attestation of Conformity No. 1191050

This type of Class E_A / Category 6A screened two connector channel has been tested by 3P Third Party Testing and complies with the Class E_A requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018 and edition 3.0 of IEC 61935-1:2009. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following BRITICOM components:

<i>Cables:</i>	<i>Horizontal Cable, Qualification Status:</i>	<i>P/N SF-UTPC6ALSGN305-P Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack: Patch panel: Qualification Status:</i>	<i>P/N STPC6ATFKSJ180SLV with PCB marking 180102 EM-298 P/N STPC6AKSJ24VS-P with PCB marking EM-298 Manufacturer Verified</i>
<i>Patch Cords:</i>	<i>5,0 m Qualification Status:</i>	<i>P/N S-FTPC6AGY3P-E, with PCB marking 120- 00050-4190_B1 THS E221000 Manufacturer Verified</i>

Hoersholm, 6th March 2019



Ole Lambertsen
Test Responsible

Hoersholm, 6th March 2019



Jens Rytter Petersen
General Manager