



Compliance Statement

Unscreened Category 6_A ISO/IEC, EN & ANSI/TIA Communication Cable

General Cable CelCat Identification:

JETLAN6A U/UTP 4PR 23AWG CAT6A 500 MHz, LSZH

Category 6_A Unscreened


100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

General Cable CelCat, Energia e Telecomunicacoes, S.A.
Av. Marques de Pombal, 36-38,
PT-2715-055, Morelena-Pero Pinheiro, Portugal

Compliance Statement No. 0473-3P-1190642

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6_A performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, the Category 6_A requirements of ANSI/TIA Generic Cabling Standard 568.2-D:2018, edition 2.1 of IEC Cable Standard 61156-5:2012 and the requirements of CENELEC Cable Standard EN 50288-11-1:2013. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 5. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 20th November 2019



Ole Lambertsen
Test Responsible

Hoersholm, 20th November 2019



Jens Rytter Petersen
General Manager