



Compliance Statement

Unscreened Category 6_A ISO/IEC, EN & ANSI/TIA Communication Cable

Leviton Identification AC6U-Dca-*

Category 6_A, Unscreened

100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

Leviton Manufacturing UK Limited
Viewfield Industrial Estate, Glenrothes
Fife KY6 2RS, Scotland

Compliance Statement No. 0473-3P-1190671

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6_A performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, ANSI/TIA Generic Cabling Standard 568.2-D:2018, 2.1 edition of IEC Cable Standard 61156-5:2012 and the requirements of CENELEC Cable Standard EN 50288-11-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 6. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 26th September 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 26th September 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen
General Manager