



# Attestation of Conformity

## ISO/IEC, EN & TIA Unscreened Class E<sub>A</sub> / Category 6A Three Connector Permanent Link

**Leviton Manufacturing UK Limited  
Viewfield Industrial Estate, Glenrothes  
Fife KY6 2RS, Scotland**

**Attestation of Conformity No. 0473-3P-1190995**

*This type of Class E<sub>A</sub> / Category 6A unscreened three connector permanent link has been tested by 3P Third Party Testing and complies with the Class E<sub>A</sub> requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018, and Category 6A requirements of ANSI/TIA-568.2-D:2018, IEEE P802.3an and edition 3.0 of IEC 61935-1:2009. The Attestation of Conformity is only valid for the actually tested permanent link samples in T568B configuration connected with RJ 45 plugs from patch and equipment cord P/N AC6PCF020-xxxHB, and consisting of the following Leviton components:*

<i>Cables:</i>	<i>Horizontal Cable (75 m), Qualification Status:</i>	<i>P/N AC6U-Eca-*2, where *= packing/length/colour Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks, Qualification Status:</i>	<i>P/N AC6JAKS000DC 10G Plus P/N AC6JAKU002 10G Plus Manufacturer verified</i>
<i>Consolidation Cord:</i>	<i>With solid conductors (15 m), Qualification Status:</i>	<i>P/N CP-AC6PCG150-xxxHSC Manufacturer verified</i>

Hoersholm, 10<sup>th</sup> December 2019

Ole Lambertsen  
Test Responsible

Hoersholm, 10<sup>th</sup> December 2019

Jens Rytter Petersen  
General Manager