



Attestation of Conformity

ISO/IEC, EN & TIA Unscreened Class E_A / Category 6A Four Connector Channel

**Leviton Manufacturing UK Limited
Viewfield Industrial Estate, Glenrothes
Fife KY6 2RS, Scotland**

Attestation of Conformity No. 0473-3P-1190996

This type of Class E_A / Category 6A unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E_A requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018, and the category 6A requirements of ANSI/TIA-568.2-D:2018, IEEE P802.3an and edition 3.0 of IEC 61935-1:2009. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration and consisting of the following Leviton components:

<i>Cables:</i>	<i>Horizontal Cable (75 m),</i>	<i>P/N AC6U-Eca-*2, where * = packing/length/colour</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks,</i>	<i>P/N AC6JAKS000DC 10G Plus</i>
		<i>P/N AC6JAKU002 10G Plus</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Consolidation Cord:</i>	<i>With solid conductors (15 m)</i>	<i>P/N CP-AC6PCG150-xxxHSC</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Patch and equipment Cords:</i>	<i>2,0 m, 3,0 m and 5,0 m,</i>	<i>P/N AC6PCF020-xxxHB</i>
		<i>P/N AC6PCF030-xxxHB</i>
		<i>P/N AC6PCF050-xxxHB</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>

Hoersholm, 10th December 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 10th December 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager