



# Attestation of Conformity

## ISO/IEC, EN & TIA Unscreened Class E / Category 6 Four Connector Channel

**Leviton Manufacturing UK Limited  
Viewfield Industrial Estate, Glenrothes  
Fife KY6 2RS, Scotland**

**Attestation of Conformity No. 0473-3P-1200190**

*This type of Class E<sub>A</sub> / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018, and the category 6 requirements of ANSI/TIA-568.2-D:2018 and edition 3.0 of IEC 61935-1:2009. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration and consisting of the following Leviton components:*

<i>Cables:</i>	<i>Horizontal Cable (75 m), Qualification Status:</i>	<i>P/N C6U-Dca-*4, where * = packing/length/colour Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack, Qualification Status:</i>	<i>P/N 61UJK-Rx6 Manufacturer verified</i>
<i>Consolidation Cord:</i>	<i>With solid conductors (15 m) Qualification Status:</i>	<i>P/N C6U-Dca-*4 Manufacturer verified</i>
<i>Patch and equipment Cords: 2,0 m, 3,0 m and 5,0 m,</i>	<i>Qualification Status:</i>	<i>P/N C6CPCU020-888-BB P/N C6CPCU030-888-BB P/N C6CPCU050-888-BB Manufacturer verified</i>

Hoersholm, 7<sup>th</sup> February 2020

A handwritten signature in blue ink, appearing to read 'Ole Lambertsen', is written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 7<sup>th</sup> February 2020

A handwritten signature in blue ink, appearing to read 'Jens Rytter Petersen', is written over a horizontal line.

Jens Rytter Petersen  
General Manager