



# Attestation of Conformity

## ISO/IEC, EN & TIA Unscreened Class E / Category 6 Four Connector Channel

**Leviton Manufacturing UK Limited  
Viewfield Industrial Estate, Glenrothes  
Fife KY6 2RS, Scotland**

**Attestation of Conformity No. 0473-3P-1200204**

*This type of Class E / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018, and the category 6 requirements of ANSI/TIA-568.2-D:2018 and edition 3.0 of IEC 61935-1:2009. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration and consisting of the following Leviton components:*

|                                   |   |   |
|-----------------------------------|---|---|
| <i>Cables:</i>                    | <i>Horizontal Cable (73 m),<br/>Qualification Status:</i>     | <i>P/N C6U-B2ca-*4, where * = packing/length/colour<br/>Manufacturer verified</i>               |
| <i>Conn. Hardware:</i>            | <i>Modular Jack,<br/>Qualification Status:</i>                | <i>P/N C6CJAKU002<br/>Manufacturer verified</i>   |
| <i>Consolidation Cord:</i>        | <i>With solid conductors (10 m)<br/>Qualification Status:</i> | <i>P/N C6U-B2ca-*4, where * = packing/length/colour<br/>Manufacturer verified</i>               |
| <i>Patch and equipment Cords:</i> | <i>2,0 m and 5,0 m,<br/>3,0 m<br/>Qualification Status:</i>   | <i>P/N 6H460<br/>P/N C6U-B2ca-*4, where * = packing/length/colour<br/>Manufacturer verified</i> |

Hoersholm, 7<sup>th</sup> February 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 7<sup>th</sup> February 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen  
General Manager