



Compliance Statement

Screened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

Schneider Electric P/N VDICD626228

**Category 6, Two Individual Foil without Overall Foil Screen Unit
100 Ω , 2x4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable**

Schneider Electric Industries SAS

35 rue Joseph Monier

92500 Rueil Malmaison, France

Compliance Statement No. 0473-3P-1200448

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, ANSI/TIA Generic Cabling Standard 568.2-D:2018, edition 2.1 of IEC Cable Standard 61156-5:2012 and the requirements of CENELEC Cable Standard EN 50288-5-1:2013. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 1st April 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 1st April 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen
General Manager