



# Compliance Statement

## Screened Category 6<sub>A</sub> ISO/IEC, EN & ANSI/TIA Communication Cable

**Schneider Electric P/N VDICD62X218 / VDICD62X318**

Category 6<sub>A</sub> Individual Foil without Overall Screen  
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

**Schneider Electric Industries SAS**  
**35 rue Joseph Monier**  
**92500 Rueil Malmaison, France**

*Compliance Statement No. 0473-3P-1200452*

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6<sub>A</sub> performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2018, ANSI/TIA Generic Cabling Standard 568.2-D:2018, edition 2.1 of IEC Cable Standard 61156-5:2012 and requirements of CENELEC Cable Standard EN 50288-10-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2 The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 1<sup>st</sup> April 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 1<sup>st</sup> April 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen  
General Manager