



# Certificate of Constancy of Performance

**2652-CPR-1190603**

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**Power Cable**  
**Power cable N2XH-J 7x1,5**  
**B2ca-s1a,d0,a1**

Product detail and use see Annex 1

**Placed on the market under the name:**

**Draka Kably, s.r.o.**  
**Trebicka 777/99**  
**594 01 Velke Mezirici**  
**Czech Republic**

**Produced in the manufacturing plant:**

**Draka Kably, s.r.o.**  
**Trebicka 777/99**  
**594 01 Velke Mezirici**  
**Czech Republic**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZZ of the standard(s)

**EN 50575:2014+A1:2016**

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the


**constancy of performance of the construction product.**

This certificate was issued on 10/07/2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**3P Third Party Testing ApS**  
**Agern Alle 3**  
**2970 Hørsholm**  
**Denmark**

[www.3Ptest.dk](http://www.3Ptest.dk)

**Hørsholm, 10<sup>th</sup> July 2020**

  
**Jens Rytter Petersen**  
**General Manager**

  
**DANAK**  
PROD Reg.No. 7041




**Annex 1**  
**Certificate of Constancy of Performance**

**2652-CPR-1190603**

<b>Common use of the product</b>	
Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.	
<b>Product family:</b>	
<b>Cable Identification:</b>	<b>Product parameter variations</b>
<b>Description</b>	<b>OD/mm</b>
20311192 - N2XH-J 7x1,5RE BK DRUM 500M CPR	15,0

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark  
[www.3Ptest.dk](http://www.3Ptest.dk)

Hørsholm, 10<sup>th</sup> July 2020  
  
Jens Rytter Petersen  
General Manager

  
**DANAK**  
PROD Reg.No. 7041