



Compliance Statement

Screened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

General Cable CelCat Identification:

JETLAN5E+ F/UTP 4PR 24AWG CAT5E 200 MHz, LSZH

Category 5e, Screened

100 Ω , 4 Twisted Pairs, 24 AWG, Flame Retardant, LSHF, Copper Cable

General Cable CelCat, Energia e Telecomunicacoes, S.A.
Av. Marques de Pombal, 36-38,
PT-2715-055 Morelena-Pero PinHeiro, Portugal

Compliance Statement No. 0473-3P-1200232

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 5e requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-3-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014 edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 9. September 2021.

Hoersholm, 9 September 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 9 September 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager