



# Compliance Statement

## Unscreened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Two Connector Channel

**BlueLine Networking  
Primavera, 14,  
28850 Torrejon de Ardoz, Spain**

**Compliance Statement No. 0473-3P-1201033**

*This type of Class EA / Category 6A Unscreened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 16 January 2023.*

<i>Cables:</i>	<i>Horizontal Cable (90,0 m), Flexible cable, Qualification Status:</i>	<i>P/N BL6A100 From patch cords P/N BL6A450 Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Patch Panel, Modular Jack, Qualification Status:</i>	<i>P/N BL6A320 P/N BL6A200 Manufacturer verified</i>
<i>Patch Cords:</i>	<i>5,0 m, Qualification Status:</i>	<i>P/N BL6A450 Manufacturer verified</i>

Hoersholm, 16 July 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 16 July 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen  
General Manager