



Compliance Statement

Unscreened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

TATUNG CO. LAN CABLE CAT. 6

Cat. 6, Overall Unscreened Cable with Unscreened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, PVC, Copper Communication Cable

Tatung Co.
106 Minshing Road, Neihai Village, Taoyuan,
Taoyuan County, Taiwan, R.O.C.

Compliance Statement No. 0473-3P-1201490

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-6-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 11 November 2021.

Hoersholm, 11 November 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 11 November 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen
General Manager