



# Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**Draka – a brand of the Prysmian Group**

**Draka Prysmian Ident.: UC900 HS23 Cat.7 S/FTP 2×4P LSHF-FR**

**Cat. 7, Overall Braid Screened Cable with Foil Screened Twisted Pairs**

**100 Ω, 2x4 Twisted Pairs, 23 AWG, Fire Retardant, LSFRHF, Copper Communication Cable**

**Draka Comteq Germany GmbH & Co. KG**

**Piccoloministrasse 2,**

**51063 Köln, Germany**

**Compliance Statement No. 0473-3P-1201502**

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of Enhanced ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-4-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Fire retardancy is verified according to IEC 60332-3-24:2018, IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 16 November 2021.*

Hoersholm, 16 November 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 16 November 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen  
General Manager