



# Compliance Statement

## Screened Category 6A ISO/IEC, EN & ANSI/TIA Communication Cable

**Draka – a brand of the Prysmian Group**

**Draka Prysmian Ident.: Draka Cat. 6A U/FTP 4P LSHF-FR**

**Cat. 6A, Overall Unscreened Cable with Foil Screened Twisted Pairs**

**100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Fire Retardant, LSRHF, Copper Communication Cable**

**Draka Comteq Germany GmbH & Co. KG**

**Piccoloministrasse 2,  
51063 Köln, Germany**

**Compliance Statement No. 0473-3P-1201505**

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-10-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Fire retardancy is verified according to IEC 60332-3-24:2018, IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 16 November 2021.*

Hoersholm, 16 November 2020

A handwritten signature in blue ink, appearing to read 'Ole Lambertsen'.

Ole Lambertsen  
Test Responsible

Hoersholm, 16 November 2020

A handwritten signature in blue ink, appearing to read 'Jens Rytter Petersen'.

Jens Rytter Petersen  
General Manager