



Compliance Statement

Screened Class EA / Category 6A

ISO/IEC, EN & ANSI/TIA

Four Connector Channel

Leviton Manufacturing UK Ltd.

Viewfield Industrial Estate, Glenrothes,

KY6 2RS Fife, United Kingdom

Compliance Statement No. 0473-3P-1201757

This type of Class EA / Category 6A Screened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 23 June 2023.

Cables:	<i>Horizontal Cable (45 m), Qualification Status:</i>	<i>P/N AC6-DCZ-*(*=Length, colour and fire classification) Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack, Qualification Status:</i>	<i>P/N 6ASJK-R*6 Manufacturer verified</i>
Consolidation Cord:	<i>(15 m) Qualification Status:</i>	<i>P/N AC6DZASJR01xxyzA (xx=Length, y=No Shutter/Shutter, z=Colour) Manufacturer verified</i>
Patch and equipment Cords:	<i>2 m, 3 m, 5 m Qualification Status:</i>	<i>P/N AC6PCFxxx-yyyHB (xxx=Length, yyy=Colour) Manufacturer verified</i>

Hoersholm, 17 December 2020

Ole Lambertsen
Test Responsible

Hoersholm, 17 December 2020

Jens Rytter Petersen
General Manager