



Certificate of Constancy of Performance

2652-CPR-1186899

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**Power Cable
HXJ/NOIKLX Xtra
B2ca-s1a,d1,a1**

Product detail and use see Annex 1

Placed on the market under the name:

**NKT (Denmark) A/S
Toftegårdsvej 25
4550 Asnæs
Denmark**

Produced in the manufacturing plant:

**NKT (Denmark) A/S
Toftegårdsvej 25
4550 Asnæs
Denmark**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZZ of the standard(s)

EN 50575:2014+A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the


constancy of performance of the construction product.

This certificate was issued on 22.06.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark**

www.3Ptest.dk

Hørsholm, 12th February 2021


**Jens Rytter Petersen
General Manager**


DANAK
PROD Reg.No. 7041



Annex 1
Certificate of Constancy of Performance

2652-CPR-1186899


Common use of the product
Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

Product family: HXJ/NOIKLX Xtra

Cable Identification:	Product parameter variations		
Description	OD/mm	Copper Size/mm ²	EXAP χ
HXJ/NOIKLX Xtra 3G1,5 Coil 100	9,1	1,5	37,28
HXJ/NOIKLX Xtra 3G1,5 Bobin 300	9,1	1,5	37,28
HXJ/NOIKLX Xtra 3G1,5 Qaddy	9,1	1,5	37,28
HXJ/NOIKLX Xtra 3G1,5 Drum 500	9,1	1,5	37,28
HXJ/NOIKLX Xtra 3G2,5 Coil 100	10,0	2,5	31,97
HXJ/NOIKLX Xtra 3G2,5 Bobin 200	10,0	2,5	31,97
HXJ/NOIKLX Xtra 3G2,5 Qaddy	10,0	2,5	31,97
HXJ/NOIKLX Xtra 3G2,5 Drum 500	10,0	2,5	31,97
HXJ/NOIKLX Xtra 5G1,5 Coil 100	10,4	1,5	53,70
HXJ/NOIKLX Xtra 5G1,5 Bobin 200	10,4	1,5	53,70
HXJ/NOIKLX Xtra 5G1,5 Qaddy	10,4	1,5	53,70
HXJ/NOIKLX Xtra 5G1,5 Drum 500	10,4	1,5	53,70
HXJ/NOIKLX Xtra 5G2,5 Coil 50	11,5	2,5	44,91
HXJ/NOIKLX Xtra 5G2,5 Bobin 150	11,5	2,5	44,91
HXJ/NOIKLX Xtra 5G2,5 Qaddy	11,5	2,5	44,91
HXJ/NOIKLX Xtra 5G2,5 Drum 500	11,5	2,5	44,91

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark
www.3Ptest.dk

Hørsholm, 12th February 2021


Jens Rytter Petersen
General Manager

