



Compliance Statement

Unscreened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Four Connector Channel


**Zhejiang Ship Electronics Technology Co., Ltd.
Scientific & Technical Garden Zone
Jiang Shan Town, Ningbo City 315191, Zhejiang, China**

Compliance Statement No. 0473-3P-1210489

This type of Class E / Category 6 Unscreened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 22 May 2023.

Cables:	<i>Horizontal Cable (15 - 85 m), Flexible cable (5 m), Qualification Status:</i>	<i>P/N D165-X P/N S0500-X Manufacturer verified</i>
Conn. Hardware:	<i>Patch Panel, Modular Jack, Qualification Status:</i>	<i>P/N P197-24A P/N M255 Manufacturer verified</i>
Consolidation Cord:	<i>Modular Jack, Qualification Status:</i>	<i>P/N P197-24A and P/N M255 Manufacturer verified</i>
Patch and equipment Cords:	<i>1,0 m, 4,0 m and 5,0 m, Qualification Status:</i>	<i>P/N S0100-X, S0400-X and S0500-X Manufacturer verified</i>

Hoersholm, 29 April 2021


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 29 April 2021


Jens Rytter Petersen
General Manager