



Compliance Statement

Screened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Four Connector Channel

**Leviton Manufacturing UK Ltd.
Viewfield Industrial Estate, Glenrothes,
KY6 2RS Fife, United Kingdom**

Compliance Statement No. 0473-3P-1210503

This type of Class E / Category 6 Screened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 11 November 2023.

<i>Cables:</i>	<i>Horizontal Cable (80 m), Qualification Status:</i>	<i>P/N C6S/FTP-Cca-xyz Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack, Qualification Status:</i>	<i>P/N C6CJAKS000DC Manufacturer verified</i>
<i>Consolidation Cord:</i>	<i>5 m Qualification Status:</i>	<i>P/N AC6DZxyz Manufacturer verified</i>
<i>Patch and equipment Cords:</i>	<i>2 m, 3 m, 5 m Qualification Status:</i>	<i>P/N C6CPCSxz Manufacturer verified</i>

Hoersholm, 11 May 2021


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 11 May 2021


Jens Rytter Petersen
General Manager