



Compliance Statement

Unscreened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Four Connector Channel

**Leviton Manufacturing UK Ltd.
Viewfield Industrial Estate, Glenrothes,
KY6 2RS Fife, United Kingdom**

Compliance Statement No. 0473-3P-1210607

This type of Class EA / Category 6A Unscreened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 4 December 2023.

| | | |
|-----------------------------------|--|---|
| <i>Cables:</i> | <i>Horizontal Cable (70m), Qualification Status:</i> | <i>P/N AC6U-Cca-xz* Manufacturer verified</i> |
| <i>Conn. Hardware:</i> | <i>Modular Jack, Qualification Status:</i> | <i>P/N 6110G Manufacturer verified</i> |
| <i>Consolidation Cords:</i> | <i>15m Qualification Status:</i> | <i>P/N CP-AC6ZCxz* Manufacturer verified</i> |
| <i>Patch and equipment Cords:</i> | <i>2m, 3m, 5m Qualification Status:</i> | <i>P/N AC6PCGxz* Manufacturer verified</i> |

**x denotes variable length and z packaging information*

Hoersholm, 10 June 2021


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 10 June 2021


Jens Rytter Petersen
General Manager