



# Compliance Statement

## Unscreened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Four Connector Channel

**Leviton Manufacturing UK Ltd.  
Viewfield Industrial Estate, Glenrothes,  
KY6 2RS Fife, United Kingdom**


**Compliance Statement No. 0473-3P-1210659**

*This type of Class E / Category 6 Unscreened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 25 December 2023.*

<b>Cables:</b>	<i>Horizontal Cable (82m), Qualification Status:</i>	<i>P/N C6U-Cca-xz* Manufacturer verified</i>
<b>Conn. Hardware:</b>	<i>Modular Jack, Qualification Status:</i>	<i>P/N 61110 Manufacturer verified</i>
<b>Consolidation Cords:</b>	<i>5m Qualification Status:</i>	<i>P/N C6U-Cca-xz* Manufacturer verified</i>
<b>Patch and equipment Cords:</b>	<i>2m, 3m, 5m Qualification Status:</i>	<i>P/N C6PCUxz* Manufacturer verified</i>

*\*x denotes variable length and z packaging information*

Hoersholm, 25 June 2021

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 25 June 2021

  
Jens Rytter Petersen  
General Manager