



Compliance Statement

Unscreened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable


2E Interconnection Identification P/N S14D-000-237xx
Cat. 6, Overall Unscreened Cable with Unscreened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

2E Interconnection B.V.
Ketelmeer 9,
5347 JX Oss, Netherlands

Compliance Statement No. 0473-3P-1210971

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-6-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 8 September 2022.

Hoersholm, 8 September 2021


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Ager Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 8 September 2021


Jens Rytter Petersen
General Manager