



Compliance Statement

Screened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Two Connector Permanent Link


Legrand
128 Avenue de Lattre de Tassigny,
87045 Limoges Cedex, France

Compliance Statement No. 0473-3P-1220424

This type of Class E / Category 6 Screened Two Connector Permanent Link has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested permanent link samples, consisting of the listed components. The Compliance Statement is valid until 7 October 2024.

<i>Cables:</i>	<i>Horizontal Cable (30 - 90 m),</i>	<i>P/N 6 327 26</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack,</i>	<i>P/N LK53</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>


Hoersholm, 7 April 2022


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 7 April 2022


Jens Rytter Petersen
General Manager