



Compliance Statement

Screened Category 6A ISO/IEC, EN & ANSI/TIA Connecting Hardware

P/N TB98PBSx
Cat. 6A Screened Keystone Jack
Electrical Transmission Performance

Telebox Industries Corp.
4F, No. 306, Tatung Road, Sec 1,
221 Hsichih-Taipei, Taiwan, R.O.C.

Compliance Statement No. 0473-3P-1220591

This screened ISO/IEC, EN & ANSI/TIA Connecting Hardware, has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018 and the requirements of edition 1.0 of IEC 60603-7-51:2010. The requirements are passed using the re-embedded vectors specified in ANSI/TIA-568.2-D:2018 and IEC 60512-27-100:2011. The qualification activity includes a factory and assembly line inspection. The Compliance Statement may be suspended or withdrawn if the Keystone Jack fails to pass Maintenance Testing Performed at 6 or 12 month intervals. The Compliance Statement is valid until 20 November 2023.

Hoersholm, 20 May 2022


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 20 May 2022


Jens Rytter Petersen
General Manager