



# Compliance Statement

## Unscreened Category 6 ISO/IEC, EN & ANSI/TIA Connecting Hardware


**Logico Electroni(Ningbo) Identification LG 3151**  
Cat. 6 Unscreened Keystone Jack  
Electrical Transmission Performance

**Logico Electronic (NingBo) Co., Ltd.**  
**Room 803, Pacific Hengye Building, 158 Tai'an Middle Road,**  
**Yinzhou District, Ningbo, China**

**Compliance Statement No. 0473-3P-1230100**

*This unscreened ISO/IEC, EN & ANSI/TIA Connecting Hardware, has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-D:2018 and the requirements of edition 2.0 of IEC 60603-7-4:2010. The requirements are passed using the re-embedded vectors specified in ANSI/TIA-568.2-D:2018 and IEC 60512-27-100:2011. The qualification activity includes a factory and assembly line inspection. The Compliance Statement may be suspended or withdrawn if the Keystone Jack fails to pass Maintenance Testing Performed at 6 or 12 month intervals. The Compliance Statement is valid until 31 January 2024.*


Hoersholm, 11 January 2023

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 11 January 2023

  
Jens Rytter Petersen  
General Manager