



Compliance Statement

Screened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Two Connector Channel

Ningbo Doppler Communication Co., Ltd.
No. 19. 3rd Binhai Road, Hangzhou Bay New Zone,
Ningbo City, Zhejiang Province, China

Compliance Statement No. 0473-3P-1230060

This type of Class EA / Category 6A Screened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 19 January 2025.

Cables:	<i>Horizontal Cable (90 m), Qualification Status:</i>	<i>P/N LCL04-C6AS-90-F Manufacturer verified</i>
Conn. Hardware:	<i>Patch Panel, Modular Jack, Keystone Jack, Qualification Status:</i>	<i>P/N LPA124-C6AS, PCB marking: 185201 JKS09 P/N LKS109-C6AS, PCB marking: 185201 JKS09 P/N LKS159-C6AS Manufacturer verified</i>
Patch and equipment Cords:	<i>5 m, Qualification Status:</i>	<i>P/N LCA01-C6AS-5-F Manufacturer verified</i>

Hoersholm, 19 January 2023


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 19 January 2023


Jens Rytter Petersen
General Manager