



# Compliance Statement

## Unscreened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Two Connector Channel

**Ningbo Linkbasic Information Technology Co., Ltd.**  
**No. 19, 3rd Binhai Road**  
**Hangzhou Bay New Zone, Ningbo, China**

**Compliance Statement No. 0473-3P-1230157**

*This type of Class EA / Category 6A Unscreened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 19 January 2025.*

<b>Cables:</b>	<i>Horizontal Cable (90 m), Qualification Status:</i>	<i>P/N FA0423AUC6A Manufacturer verified</i>
<b>Conn. Hardware:</b>	<i>Modular Jack, Modular Jack, Qualification Status:</i>	<i>P/N LKC109-C6AU mounted in P/N LOD141 P/N LKC109-C6AU mounted in P/N LPA124-C6AU Manufacturer verified</i>
<b>Patch and equipment Cords:</b>	<i>5 m, Qualification Status:</i>	<i>P/N LCA01-C6AU-5 Manufacturer verified</i>

Hoersholm, 19 January 2023

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

*Independent Testing - For End User Confidence*

Hoersholm, 19 January 2023

  
Jens Rytter Petersen  
General Manager

Page 1 of 1