



# Compliance Statement

Unscreened Class EA / Category 6A

ISO/IEC, EN & ANSI/TIA

Two Connector Modular Plug Terminated Link (MPTL)

**Singapore Cables Manufacturers Pte Ltd.**

**Wholly owned by Prysmian Group**

**No. 20 Jurong Port Road,**

**619094 Jurong Town, Singapore**

**Compliance Statement No. 0473-3P-1221449**

*This type of Class EA / Category 6A Unscreened Two Connector Modular Plug Terminated Link (MPTL) has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC TR 11801-9910:2020, CENELEC EN 50173-20:2022 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested link samples, consisting of the listed components. The tested link is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 8 November 2025.*

<i>Cables:</i>	<i>Horizontal Cable (90 m), Qualification Status:</i>	<i>P/N 80045xx-yy Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack, Qualification Status:</i>	<i>P/N HDMJTF1270xx Manufacturer verified</i>
<i>Field Termination Plug:</i>	<i>Qualification Status:</i>	<i>P/N FTPUA00 Manufacturer verified</i>

Hoersholm, 8 May 2023

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 8 May 2023

  
Jens Rytter Petersen  
General Manager