



# Compliance Statement

## ISO/IEC, EN & ANSI/TIA Patch Cords

**R&MthinLine Patch Cords - 0,5 - 20 meter lengths**  
Electrical Transmission performance

**Reichle & De-Massari AG**  
**Binzstrasse 32,**  
**CH-8620 Wetzikon, Switzerland**

**Compliance Statement No. 0473-3P-1231323**

*This product series of Patch Cords has been tested by 3P Third Party Testing. The testing has shown compliance with the electrical performance requirements of edition 1.0 of ISO/IEC 11801 1:2017, CENELEC EN 50173 1:2018, ANSI/TIA 568.2-D:2018 and IEC patch cord standard 61935-2:2010. The Compliance Statement is valid for patch cord lengths between 0,5 m and 20 m. The Compliance Statement is valid until 12 January 2025.*

| Product Series                              | Category | Screening  | Cable Construction          |
|---|----------|------------|-----------------------------|
| R&MthinLine Patch Cord CU TL C6A S xxx yyyy | 6A       | Screened   | U/FTP                       |
| R&MthinLine Patch Cord CU TL C6A U xxx yyyy | 6A       | Unscreened | U/FTP (unterminated screen) |
| R&MthinLine Patch Cord CU TL C6 U xxx yyyy  | 6        | Unscreened | U/UTP                       |

xxx: cable color, yyyy: length (0.5m – 20m)

Hoersholm, 12 January 2024

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Independent Testing - For End User Confidence

Hoersholm, 12 January 2024

  
Jens Rytter Petersen  
General Manager

Page 1 of 1