



# Compliance Statement

## Unscreened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

**2E Interconnection Identification P/N S14D 000 017xx**  
Cat. 5e, Overall Unscreened Cable with Unscreened Twisted Pairs  
100  $\Omega$ , 4 Twisted Pairs, 24 AWG, Flame Retardant, PVC, Copper Communication Cable

**2E Interconnection B.V.**  
**Ketelmeer 9,**  
**5347 JX Oss, Netherlands**

**Compliance Statement No. 0473-3P-1240271**

*This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 5e requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-3-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 12 February 2025.*

Hoersholm, 12 February 2024

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 12 February 2024

  
Jens Rytter Petersen  
General Manager