



Compliance Statement

Screened Category 6A ISO/IEC, EN & ANSI/TIA Communication Cable

YFC-BonEagle Identification P/N YLC-APPP04-AX₁-LLL-cc
Cat. 6A, Patch, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω , 4 Twisted Pairs, 26 AWG, Flame Retardant, PVC, Copper Communication Cable

YFC-BonEagle Electric Co., Ltd.
No. 12-9, 130th Lane, Section 2, Chung Shan E. Road,
Hsinwu, Taoyuan, Taiwan, R.O.C.

Compliance Statement No. 0473-3P-1240323

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-10-2:2015, and the requirements of edition 4.0 of IEC 61156-6:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 26 February 2025.

Hoersholm, 26 February 2024


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 26 February 2024


Jens Rytter Petersen
General Manager