



# Attestation of Conformity

## Screened Category 6A

### Communication Cable

PoE – Type 4

Wonderful F/UTP CAT.6A LSOH / TSL2304SXX

Cat. 6A, Overall Foil Screened Cable with Unscreened Twisted Pairs  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

Wonderful Hi-Tech Co., Ltd.

17 Pei Yuan Road, Chung-Li Industrial Park,  
32063 Taoyuan City, Taiwan, R.O.C.

No. 0473-3P-1200917

*This copper communication cable has been tested by 3P Third Party Testing according to the test procedure described in ISO/IEC TS 29125:2017, appendix B.7 and B.8. as recommended in IEEE Standard 802.3bt:2018. The test was performed in closed conduit, meaning that the recommendations below are valid for installations in all pathway types. The Attestation of Conformity is valid for the tested cable, and it covers the PoE application and max. bundle size listed below. The Attestation of Conformity is valid until 17 February 2023.*

<b>PoE application</b>	<b>Max. temperature rise</b>	<b>Max. bundle size</b>
Type 3 – 600mA per pair	5°C	130
Type 3 – 600mA per pair	10°C	450*
Type 4 – 960mA per pair	5°C	22
Type 4 – 960mA per pair	10°C	82

*\*Bundles of more than 96 cables are generally not recommended.*

Hoersholm, 17 August 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 17 August 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen  
General Manager