



Compliance Statement

Unscreened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Two Connector Permanent Link

Keynet Sistemas Profesionales s.l.
Calle F Oeste nº 56, Pol. Ind. Malpica,
E-50016 Zaragoza, Spain

Compliance Statement No. 0473-3P-1201177

This type of Class E / Category 6 Unscreened Two Connector Permanent Link has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested permanent link samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 23 March 2023.

Cables:	Horizontal Cable (30 - 90 m),	P/N TD-604UT
	Qualification Status:	Manufacturer verified
Conn. Hardware:	Modular Jack,	P/N TK-6U9-5LM
	Qualification Status:	Manufacturer verified
RJ45 plugs from Patch and equipment Cords:	2 m	P/N TL-6UTJ-022
	Qualification Status:	Manufacturer verified

Hoersholm, 23 September 2020

Ole Lambertsen
Test Responsible

Hoersholm, 23 September 2020

Jens Rytter Petersen
General Manager