



# Compliance Statement

## Screened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

**Clear Power Identification P/N LESFH30442XX**

**Cat. 5e, Overall Braid and Foil Screened Cable with Unscreened Twisted Pairs  
100  $\Omega$ , 4 Twisted Pairs, 24 AWG, Flame Retardant, LSHF, Copper Communication Cable**

**Prime Wire & Cable Inc.  
280 Machlin Court, City of Industry,  
91789-3026 California, United States**

***Compliance Statement No. 0473-3P-1201364***

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 5e requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-2-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 27 October 2021.*

Hoersholm, 27 October 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 27 October 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen  
General Manager