



Compliance Statement

Screened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

Clear Power Identification P/N LESFP20142XX

Cat. 5e, Patch, Overall Braid and Foil Screened Cable with Unscreened Twisted Pairs
100 Ω , 4 Twisted Pairs, 26 AWG, Flame Retardant, PVC, Copper Communication Cable

Prime Wire & Cable Inc.
280 Machlin Court, City of Industry,
91789-3026 California, United States

Compliance Statement No. 0473-3P-1201633

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 5e requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-2-2:2013, and the requirements of edition 4.0 of IEC 61156-6:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 19 November 2021.

Hoersholm, 19 November 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 19 November 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen
General Manager