



Compliance Statement

Screen Continuity Class E / Category 6 ISO/IEC, EN & ANSI/TIA Four Connector Channel

Singapore Cables Manufacturers Pte. Ltd.
No. 20 Jurong Port Road,
619094 Jurong Town, Singapore

Compliance Statement No. 0473-3P-1200879

This type of Class E / Category 6 Screen continuity Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 16 May 2023.

Cables:	<i>Horizontal Cable 15 m - 85 m, P/N 61075XX-YY and P/N 61075</i>
	<i>Qualification Status: Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack, P/N HDMJTF1261MA</i>
	<i>Patch Panel P/N HDPPF0600BK</i>
	<i>Qualification Status: Manufacturer verified</i>
Consolidation Cord:	<i>5 m P/N PC6220XX</i>
	<i>Qualification Status: Manufacturer verified</i>
Patch and equipment Cords:	<i>2 m, 3 m, 5 m, P/N PC6220XX</i>
	<i>Qualification Status: Manufacturer verified</i>

Hoersholm, 16 November 2020

Ole Lambertsen
Test Responsible

Hoersholm, 16 November 2020

Jens Rytter Petersen
General Manager