



# Compliance Statement

## Unscreened Class E / Category 6 ISO/IEC, EN & ANSI/TIA Four Connector Channel


**Linkbasic Iberia S.L.**  
**Passeig de L' Alzina 22, Casa B**  
**08420 Canovelles (Barcelona), Spain**

**Compliance Statement No. 0473-3P-1210843**

*This type of Class E / Category 6 Unscreened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class E electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples in T568B configuration, and consisting of the following components. The Compliance Statement is valid until 26 July 2023.*

<b>Cables:</b>	<i>Horizontal Cable, Qualification Status:</i>	<i>P/N LCLA04-C6U-X Manufacturer verified</i>
<b>Conn. Hardware:</b>	<i>Modular Jack, Patch Panel, Qualification Status:</i>	<i>P/N LKC109-C6U P/N LKC109-C6U mounted in LPA124-C6U Manufacturer verified</i>
<b>Patch and equipment Cords:</b>	<i>5,0 m, 3,0 m, and 2,0 m Qualification Status:</i>	<i>P/N LCAA01-C6U-5F, P/N LCAA01-C6U-3-F P/N LCAA01-C6U-2-F Manufacturer verified</i>


Hoersholm, 26 July 2021

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 26 July 2021

  
Jens Rytter Petersen  
General Manager