



Compliance Statement

Screened Category 6A ISO/IEC, EN & ANSI/TIA Communication Cable

Zhangjiagang Twentsche Cable Co., Ltd.

Identification: P/N 66Y008001223

**Cat. 6A, Overall Foil Screened Cable with Unscreened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable**

Zhangjiagang Twentsche Cable Co., Ltd.

**o. 12 Chuangye Road, Jinfeng Town, Zhangjiagang Suzhou Cit
215625 Jiangsu Province, China**

Compliance Statement No. 0473-3P-1211069

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-10-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 22 September 2022.

Hoersholm, 22 September 2021


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 22 September 2021


Jens Rytter Petersen
General Manager