



# Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**Premium-Line Identification 207442225**


**Cat. 7, Overall Braid Screened Cable with Foil Screened Twisted Pairs  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable**

**Premium-Line Systems GmbH  
Rosenheimer Strasse 89,  
83064 Raubling, Germany**

**Compliance Statement No. 0473-3P-1230311**

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of Enhanced ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-4-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 17 February 2024.*

Hoersholm, 17 February 2023

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 17 February 2023

  
Jens Rytter Petersen  
General Manager