



# Compliance Statement

## Screened Class I / Category 8 ISO/IEC, EN & ANSI/TIA Two Connector Channel


**HCS KABLOLAMA SISTEMLERI SAN. ve TIC. A.Ş.**  
**Ikitelli Osb.Mah. 8. Cadde, Boypas Blok No:3/A**  
**Basaksehir, Istanbul, Turkey**

### **Compliance Statement No. 0473-3P-1231090**

*This type of Class I / Category 8 Screened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class I electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 8 electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 18 April 2026.*

<b>Cables:</b>	<i>Horizontal Cable 5 m - 26 m,</i>	<i>Screened Cat. 8 (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<b>Conn. Hardware:</b>	<i>Modular Jack,</i>	<i>Screened Connection Module Cat. 8 (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<b>Patch and equipment Cords:</b>	<i>2 m,</i>	<i>Screened Cat. 8 Cord (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>


Hoersholm, 18 October 2023

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

[www.3Ptest.dk](http://www.3Ptest.dk)

Hoersholm, 18 October 2023

  
Jens Rytter Petersen  
General Manager

